

SOUTHERN COATINGS, LLC



December 11, 2025

Quote To: City of Thibodaux
1219 Henry S
Thibodaux, La. 70302

Quote For: Canal St Tank- Repairs to Tank Overflow Pipe Leaks
Change Order Request # 3

AttN: **Josh Bourgeois**
John Burgo

SCOPE OF WORK

- Southern Coatings LLC will rig the leg of the tank where the 4" overflow pipe is located.
- Southern Coatings LLC will examine each weld seam. Approximately 8-10.
- There are approximately (7) weld seams that have apparent leaking. Southern Coatings LLC will weld repair each seam to stop overflow pipe leaking.
- The standoffs on the overflow pipe should be every 10' to keep the pipe stable. Southern Coatings LLC will weld standoffs from pipe to tank leg where needed. Right now the standoffs are 20' apart.
- All Exposed Piping will be SSPC-SP3 Power Tool Cleaned to remove all welding slag and to achieve a smooth surface in order to coat the piping.
- Piping will be coated as follows:
1st Spot Coat Tnemec Series 135 Chembuild @ (4-6mils)
2nd Spot Coat Tnemec Series 135 Chembuild @ (4-6mils)
3rd Coat: Finish Coat to match the existing coat on the tank exterior:
Tnemec Series 700 Hydroflon (2-3 mils)
- This quote includes all labor, equipment, supplies, hotels, fuel and etc to complete this job.

TOTAL PRICE: \$ 10,643.00

Kevin Clement/Mayor
City of Thibodaux
310 W 2nd Street
Thibodaux, La 70301

1064 Maurice Rd.
Broussard, La 70518
tina@southerncoatings.com cell: 318-359-9027

Christina Torres
Southern Coatings LLC
1064 Maurice Road
Broussard, La. 50518

Dan Foglesone, PE
Process and Control Engineering
9 Flamingo Street
New Orleans, La 70124

Christina Torres
Christina Torres/Member
Louisiana License #71151