



December 22, 2025

Quote To: City of Thibodaux

1219 Henry St.

Thibodaux, La. 70302

Quote For: Change Order #4 - Canal St Tank- Remove Wagon Wheel (Please see photos)

Attn: Dan Fogleson

## SCOPE OF WORK

- Upon entering the tank on Canal St. Southern Coatings LLC discovered that the old wagon wheel (please see photos) was still in tank since tank was built. These wagon wheels have nothing to do with the structure of the tank. These were installed when the tank was built to hold up the walls while they were welded during construction. This remaining in the tank makes it impossible to rig the tank properly and the wagon wheel is not suffice to hang rigging off of. In the past these are always cut out, one because you can't rig the interior, two it just creates another obstruction in tank that can rust and three it no longer necessary in the tank.
- Also, Upon entering the tank there is a roll around interior ladder. Also, not necessary. It is rotten, the bolts are rotting and it is a hazard to fall. However, there is the proper ladder from Roof Hatch to Floor. (There is approximately (3) feet of the top of the ladder that needs to be cut out and replaced.)
- Southern Coatings LLC will haul off all rotten metal and dispose of. Or the City of Thibodaux can request if they want it hauled to their facility.

The following quote is to Remove Wagon Wheel, Remove Rolling Ladder and Repair the Roof Hatch to Floor three feet on the top of the ladder. This will be approximately a (7) day project.

TOTAL PRICE: \$ 18,325.32

---

Kevin Clement/Mayor  
City of Thibodeaux  
310 W 2<sup>nd</sup> Street  
Thibodeaux, La 70301

*Christina Torres* *Dan M. Foglesong*

---

Christina Torres/ Member  
Southern Coatings, LLC  
1064 Maurice Road  
Broussard, La 70518

Dan Foglesone, PE  
Process and Control Engineering  
9 Flamingo Street  
New Orleans, La 70124





















